







Depuratore di Merano / Kläranlage Meran

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
03.2026

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	696.657
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,0	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	6,94	
BOD5 / BSB5	mg/l	25,00	6,67	
CSB / COD	mg/l	100,00	24,00	
NH4	mg/l	8,00	3,17	
NO3-N	mg/l	8,00***	3,36	
NO2-N	mg/l	0,60	1,00	
N-Tot / N-Gesamt	mg/l	10,00*	7,59	
P-Tot / P-Gesamt	mg/l	1,00**	0,46	

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm		Valori ottimali optimale Werte	>20	23,33	
---	--	-----------------------------------	-----	-------	---

Consumo elettrico per AE Stromverbrauch pro EW	kWh/d	0,081
Indicatore di prestazione Leistungskennwert	-	1,39

CHIAMATE - ALLARMI ANRUFE - ALARME	
---------------------------------------	--

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.