

Depuratore di Bolzano / Kläranlage Bozen


Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
02.2021

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	1.152.079
-------------------------------------------------	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,32	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	8,60	
BOD5 / BSB5	mg/l	25,00	5,13	
CSB / COD	mg/l	100,00	24,89	
NH4-N	mg/l	8,00	0,93	
NO3-N	mg/l	8,00***	4,54	
NO2-N	mg/l	0,60	0,15	
N-Tot / N-Gesamt	mg/l	10,00*	6,26	
P-Tot / P-Gesamt	mg/l	1,00**	0,32	

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	25,83	
-------------------------------------------------	---	-----------------------------------	-----	-------	---------------------------------------------------------------------------------------

CHIAMATE - ALLARMI ANRUFE - ALARME	10	
---------------------------------------	----	---------------------------------------------------------------------------------------

Numero di interventi di reperibilità al di fuori dell'orario di lavoro
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.