



Depuratore di Bolzano / Klaieranlage Bozen

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
04.2021

|   |                  |
|---|------------------|
| <b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b> | <b>1.104.629</b> |
|---|------------------|

| PARAMETRO / PARAMETER                     | LIMITE/GRENZWERT | VALORE / WERT |       |   |
|---|------------------|---------------|-------|---|
| Solidi sedimentabili<br>Absetzbare Stoffe | ml/l             | ---           | 0,02  |    |
| Solidi sospesi totali<br>Schwebestoffe    | mg/l             | 35,00         | 5,05  |    |
| BOD5 / BSB5                               | mg/l             | 25,00         | 4,13  |    |
| CSB / COD                                 | mg/l             | 100,00        | 24,11 |    |
| NH4-N                                     | mg/l             | 8,00          | 0,93  |   |
| NO3-N                                     | mg/l             | 8,00***       | 5,05  |  |
| NO2-N                                     | mg/l             | 0,60          | 0,08  |  |
| N-Tot / N-Gesamt                          | mg/l             | 10,00*        | 6,74  |  |
| P-Tot / P-Gesamt                          | mg/l             | 1,00**        | 0,33  |  |

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

|   |   |                                   |     |       |   |
|---|---|-----------------------------------|-----|-------|---|
| Sostanza secca fango<br>Trockensubstanz Schlamm | % | Valori ottimali<br>optimale Werte | >24 | 25,10 |  |
|---|---|-----------------------------------|-----|-------|---|

|                                       |    |   |
|---------------------------------------|----|---|
| CHIAMATE - ALLARMI<br>ANRUFE - ALARME | 12 |  |
|---------------------------------------|----|---|

Numero di interventi di reperibilità al di fuori dell'orario di lavoro  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.