











Depuratore di Bolzano / Klaieranlage Bozen

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
07.2021

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>1.407.837</b>
---	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,02	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	3,45	
BOD5 / BSB5	mg/l	25,00	3,86	
CSB / COD	mg/l	100,00	19,68	
NH4-N	mg/l	8,00	0,69	
NO3-N	mg/l	8,00***	4,33	
NO2-N	mg/l	0,60	0,07	
N-Tot / N-Gesamt	mg/l	10,00*	5,92	
P-Tot / P-Gesamt	mg/l	1,00**	0,70	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	25,30	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI ANRUF - ALARME	8	
--------------------------------------	---	---

Numero di interventi di reperibilità al di fuori dell'orario di lavoro  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.