










Depuratore di Bolzano / Klaieranlage Bozen

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
10.2021

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>1.366.450</b>
---	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,19	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	7,95	
BOD5 / BSB5	mg/l	25,00	4,75	
CSB / COD	mg/l	100,00	24,34	
NH4-N	mg/l	8,00	0,77	
NO3-N	mg/l	8,00***	4,03	
NO2-N	mg/l	0,60	0,10	
N-Tot / N-Gesamt	mg/l	10,00*	5,84	
P-Tot / P-Gesamt	mg/l	1,00**	0,44	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	25,49	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI ANRUF - ALARME	9	
--------------------------------------	---	---

Numero di interventi di reperibilità al di fuori dell'orario di lavoro  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.