










## Depuratore di Bolzano / Klaieranlage Bozen

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
05.2022

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>1.174.506</b>
---	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,00	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	6,13	
BOD5 / BSB5	mg/l	25,00	4,67	
CSB / COD	mg/l	100,00	21,48	
NH4-N	mg/l	8,00	0,75	
NO3-N	mg/l	8,00***	4,25	
NO2-N	mg/l	0,60	0,06	
N-Tot / N-Gesamt	mg/l	10,00*	6,05	
P-Tot / P-Gesamt	mg/l	1,00**	0,24	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	24,21	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI ANRUFEN - ALARME	3	
--	---	---

Numero di interventi di reperibilità al di fuori dell'orario di lavoro  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.