










Depuratore di Bolzano / Klaieranlage Bozen

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
10.2022

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	1.168.416
---	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	1,48	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	17,00	
BOD5 / BSB5	mg/l	25,00	4,63	
CSB / COD	mg/l	100,00	23,42	
NH4-N	mg/l	8,00	0,74	
NO3-N	mg/l	8,00***	3,30	
NO2-N	mg/l	0,60	0,15	
N-Tot / N-Gesamt	mg/l	10,00*	5,09	
P-Tot / P-Gesamt	mg/l	1,00**	0,52	

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>24	25,41	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI ANRUF - ALARME	11	
--------------------------------------	----	---

Numero di interventi di reperibilità al di fuori dell'orario di lavoro
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.