













## Depuratore di Pontives / Kläranlage Pontives

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
03.2022

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>284.718</b>
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT	
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	2,3 
Solidi sospesi totali Schwebestoffe	mg/l	35,00	22,18 
BOD5 / BSB5	mg/l	25,00	7,90 
CSB / COD	mg/l	100,00	40,0 
NH4-N	mg/l	----	3,41 
NO3-N	mg/l	12,00***	7,32 
NO2-N	mg/l	0,60	0,06 
N-Tot / N-Gesamt	mg/l	15,00*	13,2 
P-Tot / P-Gesamt	mg/l	2,00**	1,64 

\*con concentrazione in ingresso < 50 mg/l e temperatura >= 12°C \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l und Wassertemperatur >= 12°C \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>22	23,3	
---	---	-----------------------------------	-----	------	---

CHIAMATE - ALLARMI prio 1 ANRUFEN - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFEN - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.

Temperatura Ingresso Zulauf Temperatur	9,6
---	-----