



Depuratore di Bronzolo / Kläranlage Branzoll

Valori di depurazione ottenuti nell'anno
Reinigungswerte erhalten im Jahr
2021

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	3.432.576
---	------------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,0	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	11	
BOD5 / BSB5	mg/l	25,00	7	
CSB / COD	mg/l	100,00	35	
NH4-N	mg/l	8,00	1,50	
NO3-N	mg/l	8,00***	3,44	
NO2-N	mg/l	0,60	0,46	
N-Tot / N-Gesamt	mg/l	10,00*	6,71	
P-Tot / P-Gesamt	mg/l	1,00**	0,45	

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>18	20,0	
---	---	-----------------------------------	-----	------	--