




Depuratore di Bronzolo / Kläranlage Branzoll

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
01.2021

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>298.308</b>
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,0	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	11	
BOD5 / BSB5	mg/l	25,00	14	
CSB / COD	mg/l	100,00	33	
NH4-N	mg/l	8,00	0,33	
NO3-N	mg/l	8,00***	3,81	
NO2-N	mg/l	0,60	0,30	
N-Tot / N-Gesamt	mg/l	10,00*	5,74	
P-Tot / P-Gesamt	mg/l	1,00**	0,40	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>18	18,9	
---	---	-----------------------------------	-----	------	---

CHIAMATE - ALLARMI prio 1 ANRUFE - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFE - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.