










Depuratore di Bronzolo / Kläranlage Branzoll

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
02.2021

| | |
|---|----------------|
| ACQUA TRATTATA / BEHANDELTES WASSER (mc) | 310.489 |
|---|----------------|

| PARAMETRO / PARAMETER | LIMITE/GRENZWERT | VALORE / WERT | | |
|---|------------------|---------------|------|---|
| Solidi sedimentabili Absetzbare Stoffe | ml/l | --- | 0,1 |  |
| Solidi sospesi totali Schwebestoffe | mg/l | 35,00 | 12 |  |
| BOD5 / BSB5 | mg/l | 25,00 | 7 |  |
| CSB / COD | mg/l | 100,00 | 38 |  |
| NH4-N | mg/l | 8,00 | 0,36 |  |
| NO3-N | mg/l | 8,00*** | 4,86 |  |
| NO2-N | mg/l | 0,60 | 0,29 |  |
| N-Tot / N-Gesamt | mg/l | 10,00* | 7,29 |  |
| P-Tot / P-Gesamt | mg/l | 1,00** | 0,52 |  |

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

| | | | | | |
|---|---|-----------------------------------|-----|------|---|
| Sostanza secca fango Trockensubstanz Schlamm | % | Valori ottimali optimale Werte | >18 | 19,4 |  |
|---|---|-----------------------------------|-----|------|---|

| | |
|---|--|
| CHIAMATE - ALLARMI prio 1 ANRUFE - ALARME prio 1 | |
| CHIAMATE - ALLARMI prio 2 ANRUFE - ALARME prio 2 | |

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.