











Depuratore di Bronzolo / Klaeranlage Branzoll

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
04.2022

ACQUA TRATTATA / BEHANDELTES WASSER (mc)	238.101
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	---	0,0	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	8	
BOD5 / BSB5	mg/l	25,00	5	
CSB / COD	mg/l	100,00	29	
NH4-N	mg/l	8,00	0,43	
NO3-N	mg/l	8,00***	4,08	
NO2-N	mg/l	0,60	0,18	
N-Tot / N-Gesamt	mg/l	10,00*	5,67	
P-Tot / P-Gesamt	mg/l	1,00**	0,39	

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>18	15,5	
---	---	-----------------------------------	-----	------	---

CHIAMATE - ALLARMI ANRUFE - ALARME		6
---------------------------------------	--	---

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.