

Depuratore di Termeno / Kläranlage Tramin

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
10.2023

| | |
|---|----------------|
| ACQUA TRATTATA / BEHANDELTES WASSER (mc) | 371.739 |
|---|----------------|

| PARAMETRO / PARAMETER | LIMITE/GRENZWERT | VALORE / WERT | | |
|---|------------------|---------------|-------|---|
| Solidi sedimentabili Absetzbare Stoffe | ml/l | --- | 0,00 |  |
| Solidi sospesi totali Schwebestoffe | mg/l | 35,00 | 5,94 |  |
| BOD5 / BSB5 | mg/l | 25,00 | 5,89 |  |
| CSB / COD | mg/l | 100,00 | 23,44 |  |
| NH4 | mg/l | 8,00 | 1,08 |  |
| NO3-N | mg/l | 8,00*** | 1,75 |  |
| NO2-N | mg/l | 0,60 | 0,12 |  |
| N-Tot / N-Gesamt | mg/l | 10,00* | 3,59 |  |
| P-Tot / P-Gesamt | mg/l | 1,00** | 0,26 |  |

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

| | | | | | |
|---|---|-----------------------------------|-----|-------|---|
| Sostanza secca fango Trockensubstanz Schlamm | % | Valori ottimali optimale Werte | >24 | 24,89 |  |
|---|---|-----------------------------------|-----|-------|---|

| | |
|--|--|
| CHIAMATE - ALLARMI prio 1 ANRUFTE - ALARME prio 1 | |
| CHIAMATE - ALLARMI prio 2 ANRUFTE - ALARME prio 2 | |

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.