

Termovalorizzatore Bolzano

Data: 15/07/2023

Report Medie Semiorarie

Main data table with columns for SO2, HCL, Hg, CO, POLV, NOX, COT, NH3, Q fumi, O2, T fumi, T camera, and Impianto. Rows include hourly measurements from 00:30 to 24:00.

Summary table with rows for MIN, MAX, Limite Semiorario, Intervallo confidenza, % Medie Semiorarie < Soglia 97%, and Valore Soglia 97%. Includes a final row for Media Giornata and Limite Giornata.

NOTE: (1) Assenza RegISTRAZIONI Medie (4) Media Non Valida (5) Supero Limite di Legge (7) Media non calcolata (9) Fondo scala superato

Elaborazioni conformi D.Lgs n.152/2006 Le misure di emissione sono riferite ad un tenore di ossigeno del 11% Vol.

Elaborazioni del parametro CO secondo D.Lgs 152/2006 (soglia 95%) table with rows for various CO measurement conditions and their counts.

Main data table with columns for SO2, HCL, Hg, CO, POLV, NOX, COT, NH3, Q Rauchgas, O2, T Rauchgas, T Nachbrennkammer, and Anlage. Rows include time intervals from 00:30 to 24:00.

Summary table with rows for MIN, MAX, Grenzwert 1/2 h, Konfidenzintervall, % Mittelwert 1/2 h < Schwelle 97%, and Schwellenwert 97%. Includes a final row for Tagesmittelwert and Grenzwert 24 h.

- NOTE: (1) Mittelwert-Aufzeichnung nicht vorhanden (4) Ungültiger Mittelwert (5) Grenzwertüberschreitung (7) Nicht berechneter Mittelwert (9) Messbereichsendwert überschritten

Berechnungen nach GvD Nr. 152/2006 Die Ergebnisse der Emissionsmessungen beziehen sich auf einen Bezugssauerstoffgehalt von 11% Vol.

Table titled 'Berechnungen der CO-Parameter nach GvD Nr. 152/2006 (Schwelle 95%)' with rows for 140 Gültige Mittelwerte 10 Minuten von CO, 0 Gültige Mittelwerte 10 Minuten von CO über den Grenzwert von 150 mg/Nm3 (mit Anlage in Betrieb), and 100 % Gültige Mittelwerte 10 Minuten von CO unter den Grenzwert von 150 mg/Nm3 (mit Anlage in Betrieb).