










Depuratore di Termeno / Klaieranlage Tramin

Valori di depurazione ottenuti nel mese di
Reinigungswerte erhalten im Monat
02.2021

| | |
|---|----------------|
| ACQUA TRATTATA / BEHANDELTES WASSER (mc) | 258.649 |
|---|----------------|

| PARAMETRO / PARAMETER | LIMITE/GRENZWERT | VALORE / WERT | | |
|---|------------------|---------------|-------|---|
| Solidi sedimentabili Absetzbare Stoffe | ml/l | 0,50 | 0,09 |  |
| Solidi sospesi totali Schwebestoffe | mg/l | 35,00 | 3,53 |  |
| BOD5 / BSB5 | mg/l | 25,00 | 4,25 |  |
| CSB / COD | mg/l | 100,00 | 17,50 |  |
| NH4-N | mg/l | 8,00 | 2,75 |  |
| NO3-N | mg/l | 8,00*** | 3,70 |  |
| NO2-N | mg/l | 0,60 | 0,08 |  |
| N-Tot / N-Gesamt | mg/l | 10,00* | 8,01 |  |
| P-Tot / P-Gesamt | mg/l | 1,00** | 0,46 |  |

*con concentrazione in ingresso < 50 mg/l **con concentrazione in ingresso < 10 mg/l ***limite interno
*mit Zulaufkonzentration < 50 mg/l **mit Zulaufkonzentration < 10 mg/l ***interner Grenzwert

| | | | | | |
|---|---|-----------------------------------|-----|-------|---|
| Sostanza secca fango Trockensubstanz Schlamm | % | Valori ottimali optimale Werte | >22 | 21,50 |  |
|---|---|-----------------------------------|-----|-------|---|

| | |
|---|--|
| CHIAMATE - ALLARMI prio 1 ANRUFE - ALARME prio 1 | |
| CHIAMATE - ALLARMI prio 2 ANRUFE - ALARME prio 2 | |

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.