




Depuratore di Termeno / Klaieranlage Tramin

Valori di depurazione ottenuti nel mese di  
Reinigungswerte erhalten im Monat  
03.2021

<b>ACQUA TRATTATA / BEHANDELTES WASSER (mc)</b>	<b>208.166</b>
---	----------------

PARAMETRO / PARAMETER	LIMITE/GRENZWERT	VALORE / WERT		
Solidi sedimentabili Absetzbare Stoffe	ml/l	0,50	0,00	
Solidi sospesi totali Schwebestoffe	mg/l	35,00	4,34	
BOD5 / BSB5	mg/l	25,00	5,00	
CSB / COD	mg/l	100,00	22,00	
NH4-N	mg/l	8,00	2,56	
NO3-N	mg/l	8,00***	5,50	
NO2-N	mg/l	0,60	0,27	
N-Tot / N-Gesamt	mg/l	10,00*	10,97	
P-Tot / P-Gesamt	mg/l	1,00**	0,73	

\*con concentrazione in ingresso < 50 mg/l \*\*con concentrazione in ingresso < 10 mg/l \*\*\*limite interno  
\*mit Zulaufkonzentration < 50 mg/l \*\*mit Zulaufkonzentration < 10 mg/l \*\*\*interner Grenzwert

Sostanza secca fango Trockensubstanz Schlamm	%	Valori ottimali optimale Werte	>22	22,21	
---	---	-----------------------------------	-----	-------	---

CHIAMATE - ALLARMI prio 1 ANRUFE - ALARME prio 1	
CHIAMATE - ALLARMI prio 2 ANRUFE - ALARME prio 2	

Numero di interventi di reperibilità al di fuori dell'orario di lavoro.  
Anzahl der Bereitschaftsdienste außerhalb der Arbeitszeiten.